



SPECIFICATION:

SPECIFY THE LIGHTING STATION ABOVE THE BATHROOM VANITY. THE TOP OF THE FIXTURE SHOULD BE A MINIMUM OF 6'6" OFF THE FINISHED FLOOR TO ACCOMMODATE THE HEIGHT OF A HOTEL GUEST.

THE MC CABLE IS BROUGHT IN THROUGH THE CHASSIS KNOCKOUT AND CONNECTED TO TERMINAL CONNECTOR. NO ELECTRICAL BOX REQUIRED. ELECTRICAL POWER SHOULD BE CONTROLLED BY A LIGHT SWITCH. 120 OR 240 VOLT VERSIONS.

FIXTURE SHOULD BE MOUNTED TO A MECHANICALLY SOUND SURFACE SUCH AS WALL STUDS TO SUPPORT ITS WEIGHT. MOUNTING HOLES ARE PROVIDED IN THE CHASSIS.

POWER REQUIREMENTS:
120 VOLTS .6AMPS

LAMP SPECIFICATION:

NOMINAL LENGTH (in): 36
NOMINAL WATTAGE: 39
BULB: 2 X T5
AVG RATED LIFE (hrs): 20000
CCT (K): 3000
LUMENS: 3100
CRI: 82

	NAME	DATE
DRAWN BY:	WF	9-6-06
CHECKED BY:	PDE	9-6-06
PROJECT:		

ELECTRIC MIRROR, LLC © 2006

TITLE:

ELEMENT-26.00X56.25

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ELECTRIC MIRROR L.L.C. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ELECTRIC MIRROR L.L.C. IS PROHIBITED. COPYRIGHT 2006.

SIZE A	DWG. NO. WEB SPEC	REV A
DIMS IN INCHES	SCALE: 1:24	SHEET 1 OF 1