



SPECIFICATION:

SPECIFY THE LIGHTING STATION ABOVE THE BATHROOM VANITY. THE TOP OF THE FIXTURE SHOULD BE A MINIMUM OF 6'6" OFF THE FINISHED FLOOR TO ACCOMMODATE THE HEIGHT OF A HOTEL GUEST.

THE MC CABLE IS BROUGHT IN THROUGH THE CHASSIS KNOCKOUT AND CONNECTED TO TERMINAL CONNECTOR. NO ELECTRICAL BOX REQUIRED. ELECTRICAL POWER SHOULD BE CONTROLLED BY A LIGHT SWITCH. 120 OR 240 VOLT VERSIONS.

FIXTURE SHOULD BE MOUNTED TO A MECHANICALLY SOUND SURFACE SUCH AS WALL STUDS TO SUPPORT ITS WEIGHT. MOUNTING HOLES ARE PROVIDED IN THE CHASSIS.

POWER REQUIREMENTS:

120 VOLTS, 1.4 AMPS

LAMP SPECIFICATION:

NOMINAL WATTAGE: 55
 BULB: 3X CIRCLINE T5
 OUTSIDE DIAMETER (in): 12
 AVG RATED LIFE (hrs): 12000
 CCT (K): 3000
 LUMENS: 3200
 CRI: 82

	NAME	DATE	ELECTRIC MIRROR, LLC © 2006	
DRAWN BY:	WF	8-28-06	TITLE:	
CHECKED BY:			INTEGRITY-18.00X43.50	
PROJECT:			SIZE	DWG. NO.
PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ELECTRIC MIRROR L.L.C. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ELECTRIC MIRROR L.L.C. IS PROHIBITED. COPYRIGHT 2006.			A	WEB SPEC
				REV
			DIMS IN INCHES	SHEET 1 OF 1