



**SPECIFICATION:**

SPECIFY THE LIGHTING STATION ABOVE THE BATHROOM VANITY. THE TOP OF THE FIXTURE SHOULD BE A MINIMUM OF 6'6" OFF THE FINISHED FLOOR TO ACCOMMODATE THE HEIGHT OF A HOTEL GUEST.

THE MC CABLE IS BROUGHT IN THROUGH THE CHASSIS KNOCKOUT AND CONNECTED TO TERMINAL CONNECTOR. NO ELECTRICAL BOX REQUIRED. ELECTRICAL POWER SHOULD BE CONTROLLED BY A LIGHT SWITCH. 120 OR 240 VOLT VERSIONS.

FIXTURE SHOULD BE MOUNTED TO A MECHANICALLY SOUND SURFACE SUCH AS WALL STUDS TO SUPPORT ITS WEIGHT. MOUNTING HOLES ARE PROVIDED IN THE CHASSIS.

**POWER REQUIREMENTS:**

120 VOLTS, .4 AMPS

**LAMP SPECIFICATION:**

NOMINAL LENGTH (in): 24  
 NOMINAL WATTAGE: 24  
 BULB: 2 X T5  
 AVG RATED LIFE (hrs): 20000  
 CCT (K): 3000  
 LUMENS: 1750  
 CRI: 82

	NAME	DATE	ELECTRIC MIRROR, LLC © 2007	
DRAWN BY:	SY	4/19/07	TITLE:	
CHECKED BY:			<p style="text-align: center;"><b>QUANTUM-4- 22.00X36.00</b></p>	
PROJECT:				
<p><b>PROPRIETARY AND CONFIDENTIAL</b>          THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ELECTRIC MIRROR L.L.C. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ELECTRIC MIRROR L.L.C. IS PROHIBITED. COPYRIGHT 2007.</p>			SIZE <b>A</b>	DWG. NO. <b>WEB SPEC</b>
			REV <b>A</b>	
DIMS IN INCHES		SCALE: 1:12	SHEET 1 OF 1	